

CLAY COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PO BOX 55 HAYESVILLE, NC 28904
PHONE 828-389-8326 FAX 828-389-9875

IMPROVEMENT PERMIT/CONSTRUCTION AUTHORIZATION

EXPIRATION DATE

NEW REPAIR _____ EXPANSION _____

12-2-10

TYPE OF STRUCTURE: RESIDENCE

NUMBER OF BEDROOMS: 4 PROJECTED DAILY FLOW: 480 (GPD)

TYPE OF WATER SUPPLY: Public PRIVATE---SHARED---PUBLIC---SPRING

BASEMENT CRAWLSPACE _____ SLAB _____ OVERALL DIMENSIONS 50' x 40'

INSTALLATION REQUIREMENTS/CONDITIONS

TYPE OF SYSTEM: 2 1/2" REDUCTION (INITIAL)

DRIP IRRIGATION (REPAIR)

SEPTIC TANK SIZE: 1,000 (GALLONS) PUMP TANK SIZE: N/A (GALLONS)

PUMP SPECS: N/A

TOTAL TRENCH LENGTH: 270 (FEET) TRENCH SPACING: 9 (FEET) ON CENTER

TRENCH DEPTH: 18" (INCHES) CONDITIONS: ON CURB

THE ISSUANCE OF THIS PERMIT IN NO WAY GUARANTEES THE ISSUANCE OF OTHER PERMITS. THE PERMIT HOLDER IS RESPONSIBLE FOR CHECKING WITH APPROPRIATE GOVERNING BODIES IN MEETING THEIR REQUIREMENTS. THIS SITE IS SUBJECT TO REVOCATION IF THE SITE, PLAN, OR INTENDED USE CHANGES. THIS PERMIT IS SUBJECT TO COMPLIANCE WITH THE PROVISIONS OF THE LAWS AND RULES FOR SEWAGE TREATMENT AND DISPOSAL AND TO THE CONDITIONS OF THIS PERMIT.

I UNDERSTAND AND ACCEPT THE CONDITIONS OF THIS PERMIT _____ (OWNER) _____ (AGENT)

SIGNATURE: Herry Bowler DATE: 12-2-05

AUTHORIZED STATE AGENT: [Signature] #192441 DATE: 12-2-05

SEE ATTACHED SITE SKETCH

PROPERTY OWNER
SUBDIVISION & LOT #
ADDRESS
Alb & TS, FRED
25
DAN KNOB

CLAY COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH DIVISION
 PO BOX 55 HAYESVILLE, NC 28904
 PHONE 828-389-8326 FAX 828-389-9875

IMPROVEMENT PERMIT/CONSTRUCTION AUTHORIZATION


[Handwritten Signature]
 AUTHORIZED STATE AGENT

12-2-05
 DATE

MINIMUM SETBACKS/DISTANCE REQUIREMENTS FOR SEPTIC SYSTEMS AND STRUCTURES

- 5 FEET FROM BUILDING FOOTER/FOUNDATION OF PORCH FOOTER
- 25 FEET UPSLOPE FROM BACKFILLED BASEMENT WALL
- 15 FEET UPSLOPE FROM EMBANKMENTS OR CUTS
- 50 FEET FROM ANY STREAM, CREEK, POND, OR LAKE
- 100 FEET FROM WATER SUPPLY OR AS PERMIT CONDITIONS REQUIRE
- 10 FEET FROM PROPERTY LINE
- 15 FEET SIDESLOPE FROM BASEMENT
- 10 FEET FROM WATER LINES
- FOLLOW CONTOUR
- WITHIN 1/4 INCH PER 10 FEET

PROPERTY OWNER: ALBERTS
 SUBDIVISION & LOT #: 25
 ADDRESS: DAN KNOBS



- * HOUSE MUST BE RIGHT ON R/W (NOT DOWN THE HILL)
- * DIRT FROM BASEMENT MUST BE HAULED OFF!
- * KEEP INITIAL SYSTEM AT BOTTOM OF LOT JUST OUT OF R/W & 15' BANK SETBACK
- * LOT IS TIGHT NOT MUCH ROOM FOR ERROR
- * KEEP ON CONTOUR

SCALE _____ LOT# 25 ACRES .66

SYSTEM INSTALLER: _____ SYSTEM TYPE: _____
 WATER SUPPLY: _____ DISTANCE TO SYSTEM: _____ PUMP CHECK: _____

OPERATIONS PERMIT

 AUTHORIZED STATE AGENT DATE